

ADDENDUM NO. 3

Notice to Bidders for

Bayview Avenue Drainage Improvements

**Invitation to Bid
ITB: #2016-009**

ADDENDUM ISSUED: July 27, 2016

This Addendum forms part of the Contract Documents and modifies the original Project Manual and Specifications and Drawings dated July 7, 2016. Acknowledge receipt of this Addendum in the Bid Proposal, failure to do so may subject the Bidder to disqualification.

This Addendum is a modification to the Contract Documents as follows:

- 1) Contract Documents: Contract Drawings; Modifications to Sheet 1 of the Contract drawings shall be made as follows:
 - A. The top of frame for Structure 2 shall be 3.9'. Final grade shall be adjusted accordingly.
 - B. The top of frame for Structure 3 shall be 8.7'. Final grade shall be adjusted accordingly.
 - C. Structure 3 shall be a 7' diameter manhole.
 - D. Structure 5 shall be a minimum of a 6' diameter structure. The Contractor shall be responsible for providing the structure needed to accommodate the pipe layout.
 - E. Structure 6 shall be a 5' diameter structure.
- 2) Contract Documents: Project manual; Proposal Forms; page 3 and 4 of the proposal forms shall be replaced with the attached revised sheets 3 and 4 in this addendum (revisions are in bold).
- 3) Contract Documents: Project manual/Contract Drawings; Clarification; References to shrub replacement refer only to shrubs at the back of the sidewalk on the south side of Bayview Avenue. In lieu of replacement, the contractor may reinstall these shrubs if possible.
- 4) Contract Documents: Project manual/Contract Drawings; References to utilizing existing granite curbing shall be clarified as follows: Use of existing granite curbing (if in acceptable condition) in lieu of providing new curbing is acceptable. Regardless of whether existing or new granite curbing is used, it will be paid for in accordance with the unit price for "Granite Curbing".

- 5) Contract Documents: Contract Drawings; Sheet 1; The note stating “Remove and dispose of existing stump and restore area with topsoil, seed, fertilizer, and mulch” referring to the 36” dia. stump on the east side of the existing house #9 driveway on Bayview Ave. shall also refer to another 36” dia. stump located on the west side of the same driveway.
- 6) Contract Documents: Contract Drawings; Clarification; As part of the lump sum “Clearing & Grubbing” item, three existing 36” +/- dia. trees on the east side of the proposed pipe at station 2+50+/- shall be removed and disposed of.
- 7) Contract Documents: Project manual/Contract Drawings; Clarification; Class 3 RCP is an acceptable substitute for the single HDPE pipe trench. The limits and requirements of bedding and backfill remain the same.
- 8) Below is a list of companies attending the non-mandatory bid meeting:
 - a. Koss Construction – 860-933-4557
 - b. King Construction – 860-242-2263
 - c. Wiese Construction – 860-889-4973
 - d. United Concrete – 203-605-3414
 - e. Cherenzia Excavation – 860-629-6500

END OF ADDENDUM

9. Concrete Sidewalk,
Driveways and Ramps 375 S.F. _____

UNIT PRICE IN WORDS: _____

10. Granite Curb 60 L.F. _____

UNIT PRICE IN WORDS: _____

11. 15" HDPE Culvert 20 L.F. _____

UNIT PRICE IN WORDS: _____

12. 36" HDPE Culvert 391 L.F. _____

UNIT PRICE IN WORDS: _____

13. Double 18" RCP Class 4 Culvert 95 L.F. _____

UNIT PRICE IN WORDS: _____

14A. Catch Basins
Type "C" or "CL" 2 Ea. _____

UNIT PRICE IN WORDS: _____

14B. Catch Basins
Type "C" or "CL" – 5' dia. 1 Ea. _____

UNIT PRICE IN WORDS: _____

14C. Catch Basins
Type "C" or "CL" – 6' dia. 1 Ea. _____

UNIT PRICE IN WORDS: _____

15A. Drainage Manhole- 5' dia. 1 Ea. _____

UNIT PRICE IN WORDS: _____

15B. Drainage Manhole- 7' dia. 2 Ea. _____

UNIT PRICE IN WORDS: _____

16. Concrete Headwall 1 Ea. _____

UNIT PRICE IN WORDS: _____

17. Topsoil, Seed, Fertilize & Mulch L.S. _____

UNIT PRICE IN WORDS: _____

18. Landscaping – Shrub Replacement L.S. _____

UNIT PRICE IN WORDS: _____

19. Fencing L.S. _____

UNIT PRICE IN WORDS: _____

20. Remove & Dispose of Existing Drainage System L.S. _____

UNIT PRICE IN WORDS: _____