



**Stonington Public Works  
Invitation to Bid: #2021-002**

**Town Hall HVAC Improvements  
& Related Work**

**ADDENDUM #2**

**BIDDER RFI'S AND QUESTIONS AND ANSWERS**

**March 09, 2021**

Q1: Will air duct cleaning be part of required work?

A1: No, all existing duct work will be replaced.

Q2: Please confirm that existing controls in building are by Johnson Controls?

A2: Existing controls are Johnson Controls limited BMS system.