



## **Stonington Public Works Invitation to Bid: #2021-002**

### **Town Hall HVAC Improvements & Related Work**

#### **ADDENDUM #3**

#### **BIDDER RFI'S AND QUESTIONS AND ANSWERS #2**

**March 12, 2021**

Q3: There are some discrepancies with what you would like to use for duct insulation. Please advise if you would like 1 ½" as specified on drawing M1.0, or r-8 (3" wrap) as specified on drawing M3.0. Would you like the attic to be duct board or is duct blanket acceptable?

A3: **Blanket type (R-6) with all service jacket is acceptable.**

Q4: Are you treating the attic as an exposed area?

A4: **No. Attic is unconditioned space.**

Q5: Do you want the exhaust air in the attic to be covered or no.

A5: **Yes.**

Q6: It states that "all exposed unlined supply air, exhaust air, and outside air with rigid fiberglass board insulation having a min r-6." Please advise.

A6: **1-1/2" fiberglass duct wrap (blanket) R-6 with all service jacket on all ductwork is the intent.**