



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AK

Date: 9/8/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: ROUTE 27


GIS MH No: 1-42


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**













## Manhole Inspection Form

## Manhole Information

Inspector: BM AK

GIS MH No: 1-42

Date: 9/8/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street:

**ROUTE 27** 

Rim to Invert (ft): 9.5

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: NO

Number of Holes: 0

Metal Riser: NO

Manhole Characteristics								
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments			
Frame/Cover	CAST IRON	NONE	SOUND	NONE				
Chimney	BRICK	NONE	SOUND	NONE				
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE				
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE				
Bench	BRICK	NONE	SOUND	NONE				
Invert/Channel	BRICK	NONE	SOUND	NONE				

			Inver	t Information		7.10.4
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	9,5	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	9,5	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						





# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AK

Date: 9/8/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: ROUTE 27

GIS MH No: 1-43


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**













## Manhole Inspection Form

## Manhole Information

Inspector: BM AK

GIS MH No: 1-43

Date:

9/8/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: **ROUTE 27** 

Location: PRIMARY ARTERIAL ROADS

Rim to Invert (ft): 9

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO

Number of Holes: 0

Metal Riser: NO

Infiltration: NO

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	NONE	SOUND	NONE	
Chimney	BRICK	NONE	SOUND	NONE	BRICK AND CONCRETE BLOCK
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	71
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

-			inver	t Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	9	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	9	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						



# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM/JC

Date: 5/12/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WHITEHALL AVE


GIS MH No: 1-44


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**















## Manhole Inspection Form

## Manhole Information

Inspector: BM/JC

GIS MH No: 1-44

Date: 5/12/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: WHITEHALL AVE Rim to Invert (ft):

7.25

Location: PRIMARY ARTERIAL ROADS Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: NO Number of Holes: 0

Metal Riser: YES

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	STAINS	SOUND	NONE	
Chimney	BRICK	NONE	SOUND	NONE	
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	7.25	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	7	8	CORRUGATED METAL PIPE	10:00	DEBRIS IN PIPE INVERT
Pipe 3	IN	7.25	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 4						
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM/JC

PIVIJC

Date: 5/12/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WHITEHALL AVE


GIS MH No: 1-44A


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**















## Manhole Inspection Form

## Manhole Information

Inspector: BM/JC

GIS MH No: 1-44A

Date:

5/12/2022

Type of Manhole:

SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: WHITEHALL AVE Rim to Invert (ft): 8.5

Location:

PRIMARY ARTERIAL ROADS

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: NO Number of Holes: 0

Metal Riser: YES

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	NONE	SOUND	NONE	
Chimney	BRICK	NONE	SOUND	NONE	
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

			Inver	t Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	8,5	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	8	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: JC/BM

Date: 5/12/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WHITEHALL AVE


GIS MH No: 1-44B


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)


## **Manhole Location and Configuration**















## Manhole Inspection Form

## Manhole Information

Inspector: JC/BM

GIS MH No: 1-44B

Date: 5/12/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

Weather: DRY (NO PRECIPITATION DURING SURVEY)

ENTRY)

Street:

WHITEHALL AVE

Rim to Invert (ft): 7.75

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Number of Holes: 0

Metal Riser: YES

Infiltration: NO

		Manhole Characteristics								
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments					
Frame/Cover	CAST IRON	NONE	SOUND	NONE						
Chimney	CONCRETE (PRECAST)	NONE	SOUND	NONE						
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE						
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE						
Bench	BRICK	NONE	SOUND	NONE						
Invert/Channel	BRICK	NONE	SOUND	NONE						

			Inver	t Information		7.4
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	7,75	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	7,75	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						



# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AK

GIS MH No: 1-45

Date: 9/8/2022

Type of Manhole:


Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: ROUTE 27

Inspection Status: NO ACCESS

## **Manhole Location and Configuration**











# **Manhole Inspection Form**

## Manhole Information

Inspector: BM AK

GIS MH No: 1-45

Date:

9/8/2022

Type of Manhole:

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: NO ACCESS

Street:

**ROUTE 27** 

Rim to Invert (ft):

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in):

#### Manhole Infiltration

Surcharge: Number of Holes: Infiltration: Metal Riser:

		Man	hole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover					
Chimney					
Cone					
Wall					
Bench					
Invert/Channel					
The same of the sa		- In	vert Information	- A	

			Invert	Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1						
Pipe 2						
Pipe 3						
Pipe 4		1				
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AK

Date: 9/8/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: ROUTE 27

GIS MH No: 1-46


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**













## Manhole Inspection Form

## Manhole Information

Inspector: BM AK

GIS MH No: 1-46

Date: 9/8/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street:

**ROUTE 27** 

Rim to Invert (ft): 10

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: NO Number of Holes:

Metal Riser: NO

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	NONE	SOUND	NONE	
Chimney	BRICK	NONE	SOUND	NONE	
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

Invert Information							
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments	
Pipe 1	OUT	10	18	REINFORCED PLASTIC PIPE	06:00		
Pipe 2	IN	9	8	VITRIFIED CLAY PIPE	09:00		
Pipe 3	IN	10	18	REINFORCED CONCRETE PIPE	12:00		
Pipe 4							
Pipe 5							





## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AK

Date: 9/8/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: ROUTE 27


GIS MH No: 1-47


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**















### Manhole Inspection Form

#### Manhole Information

Inspector: BM AK

GIS MH No: 1-47

Date:

9/8/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

Weather: DRY (NO PRECIPITATION DURING SURVEY)

ENTRY)

Street:

**ROUTE 27** 

Rim to Invert (ft): 11

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: NO Number of Holes:

Metal Riser: NO

**Manhole Characteristics** Location in MH Mtrl. Code Infil. Code Cond. Code Repair Codes Comments CAST IRON NONE SOUND NONE Frame/Cover SOUND NONE BRICK NONE Chimney CONCRETE (PRECAST) NONE SOUND NONE Cone CONCRETE (PRECAST) NONE SOUND NONE Wall BRICK NONE SOUND NONE Bench NONE BRICK NONE SOUND Invert/Channel

			Inver	t Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	11	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	11	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 3	IN	10	12	POLY VINYL CHLORIDE	02:00	
Pipe 4						
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM/JC

Date: 5/12/2022

3/12/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WHITEHALL AVE

GIS MH No: 1-48


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**















## Manhole Inspection Form

## Manhole Information

Inspector: BM/JC

GIS MH No: 1-48

Date: 5/12/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: WHITEHALL AVE Rim to Invert (ft): 9

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Number of Holes: 0

Infiltration: NO

Metal Riser: YES

	Manhole Characteristics							
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments			
Frame/Cover	CAST IRON	WEEPER	SOUND	NONE				
Chimney	BRICK	NONE	SOUND	NONE				
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE				
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE				
Bench	BRICK	NONE	SOUND	NONE				
Invert/Channel	BRICK	NONE	SOUND	NONE				

		Inver	t Information		
Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
OUT	9	18	REINFORCED CONCRETE PIPE	06:00	
IN	8.5	8	POLY VINYL CHLORIDE	09:00	
IN	9	18	REINFORCED CONCRETE PIPE	12:00	
	OUT	OUT 9 IN 8.5	Direction Rim to Invert Pipe Dia. (in)  OUT 9 18  IN 8.5 8	OUT         9         18         REINFORCED CONCRETE PIPE           IN         8.5         8         POLY VINYL CHLORIDE           IN         9         18         REINFORCED	Direction         Rim to Invert         Pipe Dia. (in)         Pipe Mtrl. Code         Clock Position*           OUT         9         18         REINFORCED CONCRETE PIPE         06:00           IN         8.5         8         POLY VINYL CHLORIDE         09:00           IN         9         18         REINFORCED         12:00





## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM/JC

Date: 5/12/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WHITEHALL AVE

GIS MH No: 1-49


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**















## Manhole Inspection Form

#### Manhole Information

Inspector: BM/JC

GIS MH No: 1-49

Date: 5/12/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: WHITEHALL AVE Rim to Invert (ft): 6.5

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in):

#### Manhole Infiltration

Surcharge: NO Infiltration: NO Number of Holes: 0

Metal Riser: YES

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	WEEPER	SOUND	NONE	
Chimney	BRICK	NONE	SOUND	NONE	
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

			Inver	t Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	6,5	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	6,5	18	REINFORCED CONCRETE PIPE	11:00	
Pipe 3						
Pipe 4						
Pipe 5						



# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM/JC

Date: 5/12/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WHITEHALL AVE

GIS MH No: 1-50


Type of Manhole:


SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**

















## Manhole Inspection Form

## Manhole Information

Inspector: BM/JC

GIS MH No: 1-50

Date:

5/12/2022

Type of Manhole:

SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: WHITEHALL AVE Rim to Invert (ft): 6.5

Location: PRIMARY ARTERIAL ROADS Grade to Rim (in):

#### Manhole Infiltration

Surcharge: NO Infiltration: NO Number of Holes: 0

Metal Riser: YES

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	NONE	SOUND	NONE	
Chimney	BRICK	NONE	SOUND	NONE	1
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Bench	BRICK	NONE	DEFECTIVE	CLEAN,OTHER	CLEAN SEDIMENT FROM 6-12:00. BRICKS ALSO DISPLACED IN THIS
Invert/Channel	BRICK	NONE	SOUND	NONE	AREA

			Inver	t Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	6,5	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	6	12	POLY VINYL CHLORIDE	11:00	
Pipe 3		6,5	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 4						
Pipe 5						



# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AK

GIS MH No: 1-51

Date: 9/8/2022

Type of Manhole:


Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: NO ACCESS

Street: ROUTE 27

## **Manhole Location and Configuration**











# **Manhole Inspection Form**

## Manhole Information

Inspector: BM AK

GIS MH No: 1-51

Date:

9/8/2022

Type of Manhole:

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: NO ACCESS

Street:

**ROUTE 27** 

Rim to Invert (ft):

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in):

#### Manhole Infiltration

Surcharge: **Number of Holes:** Infiltration: Metal Riser:

		Man	hole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover					
Chimney					
Cone					
Wall					
Bench					
Invert/Channel					
		In	vert Information		

			Invert	Information		
Pípe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1						
Pipe 2						
Pipe 3						
Pipe 4						
Pipe 5						



# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AK

GIS MH No: 1-52

Date: 9/8/2022

Type of Manhole:


Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: ROUTE 27

Inspection Status: NO ACCESS

## **Manhole Location and Configuration**











# **Manhole Inspection Form**

## Manhole Information

Inspector: BM AK

GIS MH No: 1-52

Date:

9/8/2022

Type of Manhole:

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: NO ACCESS

Street:

**ROUTE 27** 

Rim to Invert (ft):

Location: PRIMARY ARTERIAL ROADS

Grade to Rim (in):

#### Manhole Infiltration

Surcharge: **Number of Holes:** Infiltration: Metal Riser:

		Man	hole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover					
Chimney					_
Cone					
Wall					
Bench					
Invert/Channel					
		- In	vert Information		

			Invert	Information		
Pípe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1						
Pipe 2						
Pipe 3						
Pipe 4						
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AND JC

Date: 5/3/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: PUMP STATION

GIS MH No: 1-53


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**

















## Manhole Inspection Form

## Manhole Information

Inspector: BM AND JC

GIS MH No: 1-53

Date:

5/3/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: **PUMP STATION**  Rim to Invert (ft): 17

0

Location: PARKING LOT

Grade to Rim (in):

#### Manhole Infiltration

Surcharge: NO

Number of Holes:

Infiltration: YES

Metal Riser: NO

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	NONE	SOUND	NONE	
Chimney	BRICK	NONE	SOUND	NONE	BRICK AND CONCRETE BLOCK
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	WEEPER	DEFECTIVE	LINE_MANHOLE	
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	17	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	17	18	REINFORCED CONCRETE PIPE	09:00	
Pipe 3	IN	9,75	12	VITRIFIED CLAY PIPE	03:00	TOP OF DROP
Pipe 4	IN	17	12	VITRIFIED CLAY PIPE	03:00	BOTTOM OF DROP
Pipe 5						

Additional

**DROP IS 9.75** 

Comments



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AND JC

Date: 5/3/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: PUMP STATION


GIS MH No: 1-54


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**

















## Manhole Inspection Form

## Manhole Information

Inspector: BM AND JC

GIS MH No: 1-54

Date:

5/3/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street:

**PUMP STATION** 

Rim to Invert (ft): 10.75

Location:

EASEMENT/RIGHT OF WAY

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: YES Number of Holes:

Metal Riser: NO

Manhole Characteristics								
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments			
Frame/Cover	CAST IRON	NONE	SOUND	NONE				
Chimney	CONCRETE BLOCK	NONE	SOUND	NONE				
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE				
Wall	CONCRETE (PRECAST)	DRIPPER	DEFECTIVE	LINE_MANHOLE				
Bench	BRICK	NONE	SOUND	NONE				
Invert/Channel	BRICK	NONE	SOUND	NONE				

Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	10.75	18	REINFORCED CONCRETE PIPE	06:00	Comments
Pipe 2	IN	6,25	12	POLY VINYL CHLORIDE	07:00	
Pipe 3	IN	4.5	6	POLY VINYL CHLORIDE	10:00	
Pipe 4	IN	10.75	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 5						

Additional

0

Comments



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AND JC

Date: 5/18/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: PUMP STATION EASEMENT


GIS MH No: 1-55


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**















## Manhole Inspection Form

## Manhole Information

Inspector: BM AND JC

GIS MH No: 1-55

Date:

5/18/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street:

PUMP STATION EASEMENT

Rim to Invert (ft): 7.5

Location: WOODS Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: NO Number of Holes:

Metal Riser:

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	NONE	SOUND	NONE	
Chimney	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

	Invert Information						
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments	
Pipe 1	OUT	7.5	24	REINFORCED CONCRETE PIPE	06:00		
Pipe 2	IN	7,5	24	REINFORCED CONCRETE PIPE	01:00		
Pipe 3							
Pipe 4							
Pipe 5							



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM BAND JC

Date: 5/3/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: MILL STREET

GIS MH No: 1-56


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**



















## Manhole Inspection Form

## Manhole Information

Inspector: BM BAND JC

GIS MH No: 1-56

Date:

5/3/2022

Type of Manhole:

SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: MILL STREET Rim to Invert (ft): 12.5

Location: WOODS Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: YES Number of Holes:

Metal Riser: NO

Manhole Characteristics								
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments			
Frame/Cover	CAST IRON	WEEPER	DEFECTIVE	REPLACE FRAME AND COVER				
Chimney	CONCRETE BLOCK	NONE	SOUND	NONE				
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE				
Wall	CONCRETE (PRECAST)	STAINS	DEFECTIVE	LINE_MANHOLE,REMOVROOT IN WALL				
Bench	BRICK	NONE	SOUND	NONE				
Invert/Channel	BRICK	NONE	SOUND	NONE				

Invert Information						
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	12.5	18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	12.5	18	REINFORCED CONCRETE PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						



# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AND JC

Date: 5/3/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: MILL STREET


GIS MH No: 1-57


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**



















### Manhole Inspection Form

#### Manhole Information

Inspector: BM AND JC

GIS MH No: 1-57

Date:

5/3/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: MILL STREET Rim to Invert (ft): 10.25

WOODS Location:

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: YES Number of Holes:

Metal Riser: NO

**Manhole Characteristics** Location in MH Mtrl. Code Infil. Code Cond. Code Repair Codes Comments SOUND CAST IRON NONE NONE Frame/Cover DEFECTIVE SMALL ROOTS IN CHIMNEY BRICK NONE LINE MANHOLE AND Chimney **REMOVE ROOTS** CONCRETE (PRECAST) NONE SOUND NONE Cone CONCRETE (PRECAST) STAINS LINE\_MANHOLE, REMOVEMALL ROOTS AND STAINING DEFECTIVE Wall NONE BRICK NONE SOUND Bench NONE BRICK NONE SOUND Invert/Channel

-			Inver	t Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT		18	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN		18	REINFORCED CONCRETE PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AND JC

Date: 5/6/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WASHINGTON ST


GIS MH No: 1-63


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**

















## Manhole Inspection Form

## Manhole Information

Inspector: BM AND JC

GIS MH No: 1-63

Date: 5/6/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: **WASHINGTON ST**  Rim to Invert (ft): 11

Location: SECONDARY ROADS Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: YES Number of Holes: 4

Metal Riser: NO

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	NONE	BROKEN	REPLACE FRAME AND COVER	COVER DOES NOT HAVE HANDLES
Chimney	BRICK	NONE	SOUND	NONE	BRICK AND CONCRETE BLOCK
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	WEEPER	DEFECTIVE	LINE_MANHOLE	LOTS OF SEDIMENT AS WELL FROM INFILTRATION
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

the state of		and the same of the same of	W	t Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	11	8	VITRIFIED CLAY PIPE	06:00	
Pipe 2	IN	11	8	VITRIFIED CLAY PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AK

Date: 9/8/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: 34 WASHINGTON STREET


GIS MH No: 1-64


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE


ENTRY)

## **Manhole Location and Configuration**

















## Manhole Inspection Form

## Manhole Information

Inspector: BM AK

GIS MH No: 1-64

Date: 9/8/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: 34 WASHINGTON STREET

Rim to Invert (ft): 9

Location: SECONDARY ROADS

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO

Number of Holes: 0

Infiltration: YES

Metal Riser: NO

Manhole Characteristics							
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments		
Frame/Cover	CAST IRON	NONE	SOUND	RESET EXISTING FRAME AND CHIMNEY			
Chimney	CONCRETE BLOCK	NONE	SOUND	NONE			
Cone	CONCRETE (PRECAST)	WEEPER	DEFECTIVE	LINE_MANHOLE			
Wall	CONCRETE (PRECAST)	WEEPER	DEFECTIVE	LINE_MANHOLE			
Bench	BRICK	NONE	SOUND	NONE			
Invert/Channel	BRICK	NONE	SOUND	NONE			

			Inver	t Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	9	8	REINFORCED CONCRETE PIPE	06:00	
Pipe 2	IN	9	8	REINFORCED CONCRETE PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: TR/TT

Date: 9/28/2020

Weather: DRY WEATHER, BUT WET GROUND

Street: WASHINGTON AT JACKSON

GIS MH No: 1-65


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**













## Manhole Inspection Form

#### Manhole Information

Inspector: TR/TT

GIS MH No: 1-65

Date:

9/28/2020

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY WEATHER, BUT WET GROUND

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Comments

Street: WASHINGTON AT JACKSON

NO

BRICK

Rim to Invert (ft): 10.2

Location: LOCAL RURAL STREETS

Grade to Rim (in): 0

#### Manhole Infiltration

SOUND

Surcharge: NO

Infiltration:

Number of Holes: 26

> Metal Riser: NO

> > NONE

NONE

			The state of the s		
		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	
Frame/Cover	CAST IRON	NONE	SOUND	NONE	

Chimney CONCRETE (PRECAST) NONE SOUND NONE

NONE

CONCRETE (PRECAST) NONE SOUND

BRICK NONE SOUND NONE Bench

SOUND NONE BRICK NONE Invert/Channel

			Illivel	· mormacion		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	10.3	10	VITRIFIED CLAY PIPE	06:00	
Pipe 2	in	10.08	8	VITRIFIED CLAY PIPE	09:00	TOP OF DROP NOT MEASURED
Pipe 3	IN	10.24	10	VITRIFIED CLAY PIPE	12:00	

IN 10.16 8 VITRIFIED CLAY PIPE 03:00 Pipe 4 Pipe 5

Additional

Cone

Wall

Comments



# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AND JC

GIS MH No: 1-66

Date: 5/6/2022

Type of Manhole:


Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: NOT FOUND

Street: JACKSON AVE

## **Manhole Location and Configuration**









# **Manhole Inspection Form**

## Manhole Information

Inspector: BM AND JC

GIS MH No: 1-66

Date:

5/6/2022

Type of Manhole:

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: NOT FOUND

Street: JACKSON AVE

Rim to Invert (ft):

Location: LOCAL RURAL STREETS

Grade to Rim (in):

#### Manhole Infiltration

Surcharge: Number of Holes: Infiltration: Metal Riser:

		Man	hole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover					
Chimney					
Cone					
Wall					
Bench					
Invert/Channel					
A 100 TO		- In	vert Information		

			Invert	Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1						
Pipe 2						
Pipe 3						
Pipe 4						
Pipe 5						



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AND JC

Date: 5/6/2022

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WASHINGTON ST


GIS MH No: 1-67


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**















## Manhole Inspection Form

## Manhole Information

Inspector: BM AND JC

GIS MH No: 1-67

Date: 5/6/2022

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: **WASHINGTON ST**  Rim to Invert (ft): 8

Location: LOCAL RURAL STREETS

Grade to Rim (in): 0

#### Manhole Infiltration

Surcharge: NO Infiltration: NO Number of Holes: 2

Metal Riser:

		M	anhole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover	CAST IRON	STAINS	SOUND	REPLACE FRAME AND COVER	NO HANDLES ON COVER, MAY WANT TO REPLACE
Chimney	CONCRETE BLOCK	NONE	SOUND	NONE	
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE	
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE	<u> </u>
Bench	BRICK	NONE	SOUND	NONE	
Invert/Channel	BRICK	NONE	SOUND	NONE	

A STATE OF THE PARTY OF THE PAR			N	t Information	A STATE OF THE PARTY OF THE PAR	and the second
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	8	12	VITRIFIED CLAY PIPE	06:00	
Pipe 2	IN	8	12	VITRIFIED CLAY PIPE	12:00	
Pipe 3						
Pipe 4						
Pipe 5						



# **Manhole Inspection Form**

## **Manhole Information**

Inspector: BM AND JC

GIS MH No: 1-68

Date: 5/6/2022


Type of Manhole:


Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: NOT FOUND

Street: 11 WASHINGTON ST

## **Manhole Location and Configuration**









## Manhole Inspection Form

## Manhole Information

Inspector: BM AND JC

GIS MH No: 1-68

Date:

5/6/2022

Type of Manhole:

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: NOT FOUND

Street: 11 WASHINGTON ST Location: LOCAL RURAL STREETS Rim to Invert (ft):

Grade to Rim (in):

#### Manhole Infiltration

Surcharge: Number of Holes: Infiltration: Metal Riser:

		Man	hole Characteristics		
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments
Frame/Cover					
Chimney					
Cone					
Wall					
Bench					
Invert/Channel					
		- 75	Vert Information		

			Invert	Information		
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1						
Pipe 2						
Pipe 3						
Pipe 4		1			!	
Pipe 5						

Additional
Comments



## **Manhole Inspection Form**

## **Manhole Information**

Inspector: TT/TR

Date: 10/19/202

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Street: WILLOW AT WASHINGTON


GIS MH No: 1-69


Type of Manhole: SANITARY SEWER (GRAVITY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

## **Manhole Location and Configuration**













## Manhole Inspection Form

## Manhole Information

Inspector: TT/TR

GIS MH No: 1-69

Date: 10/19/202

Type of Manhole: SANITARY SEWER (GRAVITY)

Weather: DRY (NO PRECIPITATION DURING SURVEY)

Inspection Status: SURFACE INSPECTION: LEVEL 1 (NO MANHOLE

ENTRY)

Street: WILLOW AT WASHINGTON Rim to Invert (ft): 7.68

Location: SECONDARY ROADS Grade to Rim (in): 0

Manhole Infiltration

Surcharge: NO Number of Holes: 4

Infiltration: NO

Metal Riser: NO

Manhole Characteristics								
Location in MH	Mtrl. Code	Infil. Code	Cond. Code	Repair Codes	Comments			
Frame/Cover	CAST IRON	NONE	SOUND	NONE				
Chimney	CONCRETE BLOCK	NONE	SOUND	NONE				
Cone	CONCRETE (PRECAST)	NONE	SOUND	NONE				
Wall	CONCRETE (PRECAST)	NONE	SOUND	NONE				
Bench	BRICK	NONE	SOUND	NONE				
Invert/Channel	BRICK	NONE	SOUND	NONE				

2442.5	25,000	THE PARTY OF THE PARTY OF	4	t Information	Total Control of	7
Pipe	Direction	Rim to Invert	Pipe Dia. (in)	Pipe Mtrl. Code	Clock Position*	Comments
Pipe 1	OUT	7.65	8	VITRIFIED CLAY PIPE	06:00	
Pipe 2	IN	7,69	8	VITRIFIED CLAY PIPE	09:00	FLOW NOT MOVING
Pipe 3	IN	7.55	8	VITRIFIED CLAY PIPE	12:00	
Pipe 4	IN	7.6	6	VITRIFIED CLAY PIPE	03:00	
Pipe 5						